PHYSICAL TESTING REPORT

Kent TN29 9JH





Tudor Roof Tile Company Limited Denge Marsh Road Lydd

FAO: Mr. Paul Lythgoe					
Report of Tests on:	Tudor Roof Tiles Handmade				
Your Reference:	Various Colours				
Lucideon Reference: (143220)-14828					
Date Reported:	23-Jul-2014	Order Number:	PjL 270614		
Date Logged:	03-Jul-2014	Date(s) of Test(s):	21-Jul-2014	to 21-Jul-2014	
Determination of Elevared Strength					

Determination of Flexural Strength

BS EN 538: 1994: Clay Roofing Tiles for Discontinuous Laying

	Flexural Strength	
No.	kN	
1	0.80	
2	1.08	
3	1.34	
4	1.13	
5	1.18	
6	1.24	
7	1.12	
8	1.32	
9	1.37	
10	1.06	
Mean	1.16	

Span: 178 mm

Does the sample comply with the BSEN1304: 2005 Clause 4.4.2? Yes

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report



Mr Simon Hall Author

This report is issued in accordance with the Conditions of Business of Lucideon Limited and relates only to the sample(s) tested. No responsibility is taken for the accuracy of the sampling unless this is done under our own supervision. This report shall not be reproduced in part without the written approval of Lucideon Limited, nor used in any way as to lead to misrepresentation of the results or their implications.

Lucideon Ltd Queens Road, Penkhull Stoke-on-Trent Staffordshire ST4 7LQ, UK Page 1 of 1

T +44 (0)1782 764428 enquiries@lucideon.com www.lucideon.com Reg. England 1960455

Lucideon is the trading name of Lucideon Limited. Registered in England No. 1960455 Registered Office as above.