## PHYSICAL TESTING REPORT





Tudor Roof Tile Company Limited Denge Marsh Road Lydd Kent TN29 9JH

FAO: Mr. Tomasz Solnica

Report of Tests on: Handmade Clay Tiles
Your Reference: Sand Faced Plain
Lucideon Reference: UK222348-14892

Date Reported: 21-Jun-2022 Order Number: TS310322

**Date Logged:** 08-Jun-2022 **Date(s) of Test(s)**: 15-Jun-2022 **to** 15-Jun-2022

**Determination of Flexural Strength** 

BS EN 538: 1994: Clay Roofing Tiles for Discontinuous Laying

	Flexural Strength
No.	kN
1	1.13
2	1.10
3	1.14
4	0.96
5	1.04
6	0.98
7	1.17
8	1.08
9	1.23
10	1.16
Mean	1.10

Span: 177 mm

Does the sample comply with the BSEN1304: 2005 Clause 4.4.2? Yes

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

**End of Test Report** 

